REEVA TECHNICAL
ACT WITH INTEGRITY

+971 52 947 4679
reeva@reevallc.com
www.reevallc.com

SERVICE REPORT

TRN NO: 100556231700003

Customer Name :	Asteco Management		No. 7944
Work order No :	Site Name : The Autograph		Location : JVC
Engineer/(s) : Paul, Oliver		Date	21/10/2026
System : Access Control System			
Work Order Type : PPM		Time Arrive: ..... Hrs ..... Mins	
		Time left: ..... Hrs ..... Mins	

Observation : *We Conduct quarterly preventive maintenance for Access Control System
To No. of Devices: 22 / Brand: pac
*We checked the doors and cleared the doors properly and we test the doors also system are working good except mentioned below
(i) Masterpanel got faulty → Due to the Masterpanel issue there is no software Communications, Some of the doors are off Condition and Cards also Can't able to add

Recommendation : (ii) South 1st floor to Masterpanel Cable has faulty → Need to replace the Cable.

Parts Used	Part No.	Qty

Parts Required	Part No.	Qty

Customer Remarks

Tayyab
Customer's Name & Signature

Contact No:

Engineer's Name & Signature R. Oliver / R. O

Contact No: 050 998 6292