Inspection Certificate

EXAMINATION AND TEST OF PRESSURE VESSEL

JOB NO: 2026/9010017 **CERTIFICATE NO: ESC/AC/C/2026/9010017-01**

Date of Inspection : 06/10/2026	**Date of Expiry : 05/10/2027**	**Issued Date : 06/10/2026**
M/s. Sharif Wooden Pallets Manufacturing LLC **Al Quoz, Dubai – United Arab Emirates**		
Type of Inspection **In-Service Inspection**	Inspection Requested by **M/s. Sharif Wooden Pallets Manufacturing LLC**	Type of Equipment **Air Compressor**
Location of Equipment **Compressor Area**	Manufacturer Name **LMF**	Identification / Serial No. **151801844**
Year of Manufactured **2018**	Model / Type **LX15-10 / Screw Type**	Capacity **1.93 m³/min**
Max. Allowable working Pressure **10.0 Bar**	Operating Pressure **8.0 Bar**	Pressure Cut-in / Cut-off **Cut in:7.0 Bar & Cut off: 8.0 Bar**
Safety Relieve device type **Spring Loaded**	Safety Relief Valve Set Pressure **14.0 Bar @ Oil Tank**	Standard Reference **NBIC Part-2:2025**
ESC Test Procedure used **ESC/ITP-101, Issue: 04, Rev 00.**	ESC Test Equipment used **ESC/R-11 Series**	Date of Last Inspection & Done by **03/10/2025 & ESC**
Equipment Status	☑ **Safe to Use**	

- This is to certify that the equipment described in this certificate was inspected and tested in accordance to the aforementioned standard and regulations and inspection results were found during the time of inspection does not affect the continued operation of the equipment and ***Safe to use.***
- We kindly advise to implement corrective action on the items mentioned overleaf and / or in the attached report.
- The certificate validity cease in the event that any alteration, substantial repair and significant changes in design or construction of the Equipment.
- This certificate shall not be reproduced except in full without the approval of Elite Safety Consultants LLC & Client
- This certificate is valid for 12 months (in accordance with EIAC-RQ-IB-004) from the date of inspection.
- All the information obtained/gathered during inspection shall be preserved as confidential.

Name and address of the company	**IB-032, ELITE SAFETY CONSULTANTS LLC** **P.O Box: 26973, DUBAI, UAE.**

Inspected by

P.O.Box 26973 DUBAI - U.A.E ELITE SAFETY CONSULTANTS L.L.C

Akash R
Inspection Engineer

Neither ELITE SAFETY CONSULTANTS LLC nor the INSPECTOR shall in any circumstances be responsible or liable to any person for omission default or negligence whatsoever.

Inspection Checklist, Findings & Annexure-01 are enclosed.

Your One Stop Safety Solution Provider

P.O Box: 26973, Dubai, UAE 04-239 2655 info@elitesafetyuae.com www.elitesafetyuae.com

1. Inspection Checklist			
Equipment ID / Serial No.	**151801844**	**Certificate No**	**ESC/AC/C/2026/9010017-01**

No.	Items checked	Findings
01	*Environmental condition*	*Satisfactory - Room Temp 38^{O}C*
02	*Document verification*	*Satisfactory*
03	*Name plate verification*	*Fixed on bottom front cover - Satisfactory*
04	*External visual examination*	*Satisfactory*
05	*Functional inspection*	*Satisfactory*
06	*Pressure gauge*	*Satisfactory, Sl.No: PG-01 (digital)*
07	*Safety valve*	*Satisfactory - Sl. No: SRV 01, Set Pressure: 14.0Bar @ Oil Tank*

2. Findings *(with target date)*			
Equipment ID / Serial No.	**151801844**	**Certificate No**	**ESC/AC/C/2026/9010017-01**

None

ELITE SAFETY CONSULTANTS L.L.C
P.O.Box 26973
DUBAI - U.A.E

Your One Stop Safety Solution Provider

P.O Box: 26973, Dubai, UAE | 04-239 2655 | info@elitesafetyuae.com | www.elitesafetyuae.com

3. **Annexure - 01** (Inspection Photos)			
Equipment ID / Serial No.	**151801844**	**Certificate No**	**ESC/AC/C/2026/9010017-01**
			
			
Name & Designation of the Person carried out the Examination & Test			
Inspected by **Akash R** Inspection Engineer			

Your One Stop Safety Solution Provider

P.O Box: 26973, Dubai, UAE | 04-239 2655 | info@elitesafetyuae.com | www.elitesafetyuae.com

CALIBRATION CERTIFICATE

Work Order/Job Number:-	J 22010	**Page No:-**	1 of 2
Certificate Number:-	C 22010001	**Calibration Date:-**	01-Apr-26
Date of Issue:-	01-Apr-26	**Calibration Due Date:-**	31-Mar-27 (On Customer Request)
Calibration Location:-	Site	**UUC Received Date:-**	01-Apr-26

CUSTOMER DETAILS

Customer Name:-	SHARIF WOODEN PALLETS MANUFACTURING LLC
Address:-	P.O BOX 390553,AL QUOZ IND. AREA 3,DUBAI,UAE

INSTRUMENT DETAILS

Instrument Name:-	Temperature controller with sensor	**Range/Size:-**	0 °C to 1000 °C
Manufacture:-	Simex	**Resolution:-**	1 °C
Model:-	---	**Accuracy:-**	± 2 °C
Serial Number:-	22010-TC-01	**Type:-**	Digital
Tag/ID No:-	---	**Steam Dia:-**	6 mm
Location:-	----		

ENVIRONMENTAL CONDITIONS

Avg. Ambient Temperature:-	23.7°C ± 0.38°C	**Avg. Relative Humidity:-**	51.5 %RH ± 2.5 %RH

INSTRUMENT CONDITIONS

Physical Received Condition:-	Good	**Any Adjustment Done:-**	No

REFERENCE STANDARD/GUIDELINE/PROCEDURE/METHOD

In House Calibration Procedure / Work Instruction:-	DA-T-001
Reference Standard Guideline:-	DKD R 5-1

REFERENCE INSTRUMENT/EQUIPMENT DETAILS

Instrument Name	Serial Number/Tag Number	Certificate Number	Calibrated by	Due Date
Digital Thermometer with RTD	2538997,2983202, / DAL/lab/048-1(3)	1000717	DCL,Dubai	10-Sep-26
Standard K Type Thermocouple Sensor	24000055	CC423625000001126F	Tempsens	22-Jun-26
Multi-Product Calibrator with Power Quality Option	3091902 / DAL/lab/018	74906	1A CAL	07-Oct-27

RESULTS OF CALIBRATION

The Results of Calibration is give in the attached Calibration Data Sheet.

Traceability Statement:- All measuring equipments used for calibration purpose is traceable to International / National Standards as per required in ISO IEC 17025. It provides traceability of measurement to the SI system of units and/or to units of measurement realised at the recognised National Metrology Institutes /Laboratory.

Uncertainty Statement:- The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k = 2, providing a level of confidence of approximately 95%. The expanded uncertainty presented in this report was calculated using methodology consistent with the ISO Guide to the Expression of Uncertainty in Measurement(GUM).

Note:- •The user should determine the suitability of the instrument for its intended use. •The results stated in this certificate are related only to the item(s) mentioned and calibrated by AL SAQR ENGINEERING Lab.•The certificate validity cease in the event that any major repair or alteration, in which case it must be recalibrated •This certificate had been issued without prejudice to any party •The given Standatd Value/readings and measured value or UUC readings are average of minimum 10 readings.

Calibrated By
Amal
Calibration Engineer

AL SAQR ENGINEERING
Al Saqr Engineering الصقر للهندسة
CERTIFIED

Approved By
Raman Kumar
Quality Manager

AL SAQR Lab is not liable for any damage caused by or resulting from improper or negligent use. This certificate is issued accordance with the accreditation requirement of the EIAC. EIAC is a signatory to the Mutual Recognition arrangements with ILAC. This certificate may not be reproduced other than in full, except with the prior written permission from AL SAQR ENGINEERING.

CALIBRATION CERTIFICATE

Certificate Number:-	C 220101001	**Page No:-**	2 of 2
Date of Issue:-	01-Apr-26	**Calibration Date:-**	01-Apr-26
Serial Number:-	22010-TC-01	**Calibration Due Date:-**	31-Mar-27 (On Customer Request)

RESULTS OF CALIBRATION

CALIBRATION DATA

Function:- Temperature Sensor With Indicator	**Range:-**	**0 °C to 1000 °C**	**Resolution:-**	**1 °C**
Accuracy:- ± 2 °C				

Calibration Point	Avg. of Standard Readings	Avg. of Instrument/UUC Readings	Accuracy	Deviation	Expanded Measurement Uncertainty (±)
0.0 °C	0.050 °C	0 °C	± 2.000 °C	-0.050 °C	± 0.6°C
50.0 °C	50.015 °C	50 °C	± 2.000 °C	-0.015 °C	± 0.6°C
100.0 °C	100.026 °C	100 °C	± 2.000 °C	-0.026 °C	± 0.6°C
150.0 °C	150.032 °C	150 °C	± 2.000 °C	-0.032 °C	± 0.6°C
200.0 °C	199.042 °C	200 °C	± 2.000 °C	0.958 °C	± 0.6°C
250.0 °C	249.03 °C	250 °C	± 2.000 °C	0.970 °C	± 0.6°C

Remarks:-	---

***** END OF CERTIFICATE *****

AL SAQR ENGINEERING
Al Saqr Engineering الصقر للهندسة
CERTIFIED

AL SAQR Lab is not liable for any damage caused by or resulting from improper or negligent use. This certificate is issued accordance with the accreditation requirement of the EIAC. EIAC is a signatory to the Mutual Recognition arrangements with ILAC. This certificate may not be reproduced other than in full, except with the prior written permission from AL SAQR ENGINEERING.

Elite Safety Consultants

Your One Stop Safety Solution Provider

Highfield Qualifications

***Highfield* Qualifications**

Certifies that

Abdul Hakeem Zakari Aryee

has successfully passed an assessment in

Highfield Level 2 International Award in Fire Safety for Fire Wardens

DISTINCTION

Date of Award 25 September 2025

Expiry Date 24 September 2027

Certificate number FIR8935993

Elite Safety Consultants

Course Director

Training Organisation

Richard Sprenger, Chairman
Highfield Qualifications

INTERNATIONAL QUALIFICATION by Highfield

A global leader for qualifications, assessment, digital solutions, innovative products, e-learning and customer service.

This is an electronic version of the certificate provided by Highfield. To verify this certificate please go to https://www.highfieldqualifications.com/checkcert

Elite Safety Consultants LLC

IB-032

Inspection Certificate

EXAMINATION AND TEST OF FORKLIFT

JOB NO: 2026/9010017 **CERTIFICATE NO: ESC/FL/C/2026/9010017-02**

Date of Inspection : 06/10/2026	Next Inspection due by : 05/10/2027	Issued Date : 06/10/2026

M/s. Sharif Wooden Pallets Manufacturing LLC
Al Quoz, Dubai, United Arab Emirates.

Inspection Requested by:	Project Detail's:	Type of Inspection:
M/s. Sharif Wooden Pallets Manufacturing LLC	**Dubai, UAE**	**In-Service**
ESC Test Procedure (s):	ESC Test Equipment used:	Applicable Standard (s):
ESC/ITP-04	**ESC-R 4 Series**	**BS 5639-1, BS ISO 22915-1,2,3,8,10,11 & 14**
Date of Last Inspection:	Last Inspection done by:	Location of Equipment:
NA	**NA**	**AL Quoz**

ID NUMBER	EQUIPMENT DESCRIPTION	INSPECTION DETAILS
511010389201005720/ 218015720	Make : **Baoli** YOM : **2018** Model : **CPCD30** Type of Power : **Diesel Powered** Max. Lifting Height : **4500 mm** Attachment : **1200 mm Fork** Traffic Plate No. : **NA** Maintenance : **In-House**	**Visual Examination, Functional Test & Load Test Done.**

SAFE WORKING LOAD (SWL)		
Load Centre	**Height**	**Capacity**
600 mm	4500 mm	**2700 Kg**
-	-	**-**
-	-	**-**

Condition of the Equipment	☑ SAFE TO USE

- This is to certify that the equipment/item described in this certificate was inspected and tested in accordance with the applicable standards and regulations, and at the time of inspection, was found **free from serious defects and safe for use.**
- The validity of this report shall cease if any alteration, substantial repair, modification, or significant changes in design or construction of the Equipment.
- We kindly advise that **if any corrective actions are mentioned**, they should be implemented for the items indicated overleaf and/or in the attached report.
- This certificate shall not be reproduced, except in full, without the prior approval of **Elite Safety Consultants LLC** and the **Client**.
- This certificate is valid for **twelve (12) months** from the date of inspection.
- All the information obtained/gathered during inspection shall be preserved as confidential.

Name and address of the company undertaking the inspection:	**IB-032, ELITE SAFETY CONSULTANTS LLC** **P.O Box: 26973, DUBAI, UAE.**

Inspected by

P.O.Box 26973 DUBAI - U.A.E ELITE SAFETY CONSULTANTS L.L.C

Akash R
Inspection Engineer

Neither ELITE SAFETY CONSULTANTS LLC nor the INSPECTOR shall in any circumstances be responsible or liable to any person for omission default or negligence whatsoever.

Checkpoints, Findings & Photos are enclosed.

Your One Stop Safety Solution Provider

P.O Box: 26973, Dubai, UAE 04-239 2655 info@elitesafetyuae.com www.elitesafetyuae.com

1. INSPECTION CHECKLIST		CERTIFICATE NO.	ESC/FL/C/2026/9010017-02		
No.	**Items checked** (S- Satisfactory, U- Unsatisfactory (see Critical Findings / Findings), N- Not Applicable)		**S**	**U**	**N**
01	*Documentations (Mfg. doc, Maintenance log, Previous inspection record, etc.).*		✓		
02	*Manufacturer details / data plate / Load Chart / Capacity Information*		✓		
03	*Operator cabin, Seat & belt, Overhead guard, Glass & Fork Control levers*			✓	
04	*Head Light, Indicators, Reverse Alarm, Revolving Beacon, etc.*			✓	
05	*Tyre & Brakes (Service & Parking)*		✓		
06	*Engine / Battery*		✓		
07	*Gauges (Battery / Fuel / Hyd. Oil level)*		✓		
08	*Hydraulic Reservoir, Pump, Cylinder, Pistons, Hoses, Supports, etc.*		✓		
09	*Lifting Chain (Marking, Wear, Elongation, Lubrication), Chain pulley, Sprockets*		✓		
10	*Forks (Marking, Wear, Straightness, Tip Alignment, Shank hook, Shank Angle)*		✓		
11	*Functional Test (Lifting, Lowering, Side Shift, Tilting)*		✓		
12	*Load Test*		✓		

2. CRITICAL FINDING *(With target date)*

None.

3. FINDING *(With target date)*

1. Operator seat found damaged, needs to be replaced/ Repaired. (Target date: 06/12/2026)
2. Revolving beacon and indicators needs to be rectified. (Target date: 06/12/2026)

ELITE SAFETY CONSULTANTS L.L.C P.O.Box 26973 DUBAI - U.A.E

Your One Stop Safety Solution Provider

P.O Box: 26973, Dubai, UAE | 04-239 2655 | info@elitesafetyuae.com | www.elitesafetyuae.com

4. INSPECTION PHOTOS	CERTIFICATE NO.	ESC/FL/C/2026/9010017-02









Name & Designation of the Person carried out the Examination & Test

Inspected by

Akash R
Inspection Engineer

ELITE SAFETY CONSULTANTS L.L.C
P.O.Box 26973
DUBAI - U.A.E

Your One Stop Safety Solution Provider

P.O Box: 26973, Dubai, UAE | 04-239 2655 | info@elitesafetyuae.com | www.elitesafetyuae.com

Safety Training

Company Name	:	**Sharif Wooden Pallets Manufacturing LLC**
Employee Name	:	**Mr. Nishan Singh Amrik Singh**
ID No	:	784-1982-2538761-6
Certificate No	:	ESC-CER-TR-9010017-01
Issued date	:	06 Oct 2026
Valid up to	:	05 Oct 2027



Has successfully completed the training course on

Forklift Operator Safety Training



Elite Safety Consultants LLC

P.O Box: 26973, Dubai, UAE. Tel: 97142392655
Email : info@elitesafetyuae.com / Website: www.elitesafetyuae.com

Safety Training

Company Name	:	**Sharif Wooden Pallets Manufacturing LLC**
Employee Name	:	**Mr. Nishan Singh Amrik Singh**
ID No	:	784-1982-2538761-6
Certificate No	:	ESC-CER-TR-9010017-0.
Issued date	:	06 Oct 2026
Valid up to	:	05 Oct 2027



Has successfully completed the training course on
Forklift Operator Safety Training

Certificate of Training

Compliance for Wood Packaging Material in International Trade (ISPM 15)

To Whomsoever It May Concern

This is to certify that ***Mr. Akhil Rajendran Kurakkottikkal Raghavan Rajendran*** *Emirates ID No. 784-1992-6532505-2, has been completed training for Phytosanitary measures required for Wood Packaging Material as per* ISPM15 *Standard at Heat Treatment Facility.*

During the training, he was exposed to training on stamp use and record keeping, technical assistance, export compliance consultation, maintenance, management, inventory control, and quality system.

Signed .....

Dated: 16th March 2026

Validity: 1 year from the date of certification

Certificate of Training

Compliance for Wood Packaging Material in International Trade (ISPM 15)

To Whomsoever It May Concern

This is to certify that ***Mr. Adelbert Villas Cabisada*** *Emirates ID No. 784-1984-5808588-7, has been completed training for Phytosanitary measures required for Wood Packaging Material as per* ISPM15 *Standard at Heat Treatment Facility.*

During the training, he was exposed to training on stamp use and record keeping, technical assistance, export compliance consultation, maintenance, management, inventory control, and quality system.

AHEM
AL ARABIAN HYDRAULIC EQUIPMENT MAINT.

Signed .....

Dated: 16th March 2026

Validity: 1 year from the date of certification

Certificate of Training

Compliance for Wood Packaging Material in International Trade (ISPM 15)

To Whomsoever It May Concern

This is to certify that **Mrs. Leah Cabisada Fernandez** *Emirates ID No. 784-1979-2410387-8, has been completed training for Phytosanitary measures required for Wood Packaging Material as per* ISPM15 *Standard at Heat Treatment Facility.*

During the training, he was exposed to training on stamp use and record keeping, technical assistance, export compliance consultation, maintenance, management, inventory control, and quality system.

AHEM
AL ARABIAN HYDRAULIC EQUIPMENT MAINT.

Signed .....

Dated: 16th March 2026

Validity: 1 year from the date of certification

ANNUAL MAINTENANCE CONTRACT
Rev# 00
JO3/JEN/3595
SMX/PRV/2026 - 258
20/April/2026
This agreement is made between

SAFE MAX FIRE & SAFETY L.L.C
P.O. Box: 97199,
Dubai, U.A.E.
(Being the first party and herein after called SAFEMAX)

AND

SHELFCO METAL INDUSTRIES LLC
P.O BOX 112532
Dubai U.A.E
(Being the second party and herein after called the CLIENT)

Sub : Annual Maintenance of Fire Alarm & Fire Fighting Systems
Contract Period: 20/April/2026 to 19/April/2027
Site : SHELFCO METAL INDUSTRIES - WAREHOUSE AT AL QUOZ, DUBAI UAE

MAINTENANCE CHARGE

Our total price for ONE year maintenance services for Fire Protection Systems, without spares will be **AED: 4,000/ - (AED: Four Thousand Dirhams Only) (Additional 5% VAT will be charge extra).**

SCOPE OF WORK

With reference to the instructions given to us by the 2nd party, we at SAFEMAX will undertake this job under the scope of work and conditions.

1. Maintenance will be provided by SAFEMAX to keep the equipment in good working order while it is being used in accordance with specification and duty cycles, NFPA and Dubai Civil Defense

2. This maintenance service will begin from the date mentioned above and will include the following:

   a. Fire protection systems repairs
   b. Preventive maintenance
   c. Complete inspection with reporting.
   d. All necessary work and engineering support.

3. Perform four periodical preventive maintenance and inspection visits during the duration of this agreement, once every three months.

- Fire Alarm System - (4) Times a year
- Fire Fighting System - (4) Times a year
- Exit and Emergency Light - (4) Times a year
- Fire Extinguisher System - (4) Times a year
- Fire Pump System - (4) Times a year

4. Attend emergency calls 24/7 days and shall respond to all such client call out. The call outs will be attended within the earliest possible time on all days. In case of emergency telephone number is **050 927 3927**, which is working **24 hours. (Maximum 4 Hours including Sundays and Public Holidays)**

SAFEMAX FIRE & SAFETY L.L.C
P.O. Box: 97199, Dubai -U.A.E.
Tel : +971 4 266 3288
Fax : +971 4 266 3290
E-mail : info@safemax.org
Website : www.safemax.org

NFPA MEMBER
DCD/EHS-CIVIL DEFENCE APPROVED
SHARJAH CIVIL DEFENCE APPROVED
ABU DHABI CIVIL DEFENCE APPROVED

سيف ماكس فاير & سيفتي ذ.م.م
ص.ب : ٩٧١٩٩ دبي -ا.ع.م
تليفون: ٣٢٨٨ ٢٦٦ ٤ ٩٧١+
فاكس : ٣٢٩٠ ٢٦٦ ٤ ٩٧١+
ايميل : info@safemax.org
ويب : www.safemax.org

MODE OF PAYMENT

50% ADVANCE PAYMENT AND 50% ON THE 3RD SERVICE

TERMS AND CONDITION

1. The client will deal exclusively with SAFEMAX appointed representative responsible for the maintenance of the equipment. Any changes of such responsibilities should be notified to the client in writing.

2. Any additional changes requested by the client will be implemented on a next call basis or at mutually convenient time at extra charge to the client.

3. SAFEMAX's service team shall have full and free access to the equipment to provide service thereon whenever it is required. SAFEMAX shall inform date of visit to the Client prior to visit to ensure that Client's Representative is present whenever SAFEMAX Representative visits the site for any maintenance work.

4. The equipment shall not be relocated from the site except by SAFEMAX personnel. Alterations, attachment or modifications of the equipment may not be made except in the presence of SAFE MAX's appointed representative.

5. Notice of any alterations should be in writing and should reach SAFEMAX at least one week in advance .Relocation will be billable at SAFEMAX commercial rates then in effect.

6. SAFEMAX undertakes to supply and install all required materials or spare parts for relocation if required subject to a separate quotation at current standard prices and would only be supplied upon receipt of an instruction from the Client's representative in writing.

7. SAFEMAX will charge additional any cost related to spare parts if required for equipment repairing , replacement & programming subject to a separate quotation at current standard prices and would only be supplied upon receipt of an instruction from the Client's representative in writing.

8. Software modifications, upgrading and or reprogramming is not included in our offer and if required will be charged extra.

9. SAFEMAX undertakes to submit a complete evaluation report/Print - out quarterly to the client. This report shall include the current status, any problems or situations arising and recommendations.

10. SAFEMAX shall have no liability for any failure of equipment due to external causes, including accidents , neglect , misuse , non-observance and other risk other than ordinary use., or if caused by attempts to repair or service or relocate the equipment made by other than SAFE Max's personnel .

11. SAFEMAX shall not be liable for breach or non-performance or delay in carrying out any of the obligations contained in this maintenance service contract as a result of accidental damage ,restrictions imposed by the government ,any act of god ,war or any condition arising from similar causes beyond SAFEMAX's control and any kind of consequential damages.

12. SAFEMAX indemnifies the CLIENT (including its personnel, subcontractors, representatives and agents) against any and all claims, losses, expenses and other liabilities (including attorney's fees) which the CLIENT may incur or which may be made against it as a result of or in connection with: Any negligence, error, omission or lack of skill, care or diligence by the or its personnel, subcontractors, representatives or agents in the provision of the Services;

13. SAFEMAX shall terminate this agreement in case of non-payment by the client or overdue invoices for the service rendered under this agreement. SAFEMAX shall have the right the suspend all maintenance service by giving seven days prior written notice.

14. The maintenance service is subject to termination by SAFEMAX if it is carried out by a third party without SAFEMAX's written approval. SAFEMAX has the option to terminate the maintenance contract in case change of ownership

16. Both parties may terminate this agreement by giving a month notice in writing prior to the termination of this agreement.

17. Any dispute arising in connection with this agreement shall, unless settled amicably, be referred for decision to a single arbitrator to be agreed upon by the parties hereto or failing to reach such agreement, to be appointed by the Dubai chamber of Commerce and Industry upon the application of either party. The decision thereafter shall be final and finding upon the parties

18. The agreement embodies the whole agreement between the parties hereto and all previous correspondence, negotiations explanation, statements, guarantees whether oral or written shall be excluded.

19. This agreement may be renewed on its expiry subject to mutual agreement of both parties.

Accepted on Behalf of:

SAFEMAX FIRE & SAFETY L.L.C
P.O BOX 97199
DUBAI, U.A.E

Name; SANU DEVASIA

Designation: CEO

Signature:

Stamp

Accepted on Behalf of:

M/S SHELFCO METAL INDUSTRIES LLC
P.O BOX 112532
Dubai U.A.E

Name; Hisham El Naffar

Designation: General Manager

Signature:

Stamp